

## PROHLÁŠENÍ O VLASTNOSTECH

DLE NAŘÍZENÍ EVROPSKÉHO PARLAMENTU A RADY EU č. 305/2011  
kterým se stanoví harmonizované podmínky pro uvádění stavebních výrobků na trh  
číslo CPR 003\_2013

- 1. Kód typu výrobku:** SD-280ST
- 2. Název výrobku:** Kombinovaný detektor kouře a teplot reléový
- 3. Zamyšlené použití:** Detekce požáru v budovách
- 4. Výrobce**  
**Obchodní jméno:** JABLOTRON ALARMS a.s.  
**Sídlo:** Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou  
**IČ:** 28668715
- 5. Pověřený zástupce:** Nestanoven
- 6. Posouzení a ověření stálosti vlastností:** Systém 1
- 7. Provedení typové zkoušky a počáteční inspekce a řízení výroby:**  
EVPÚ a.s., Trenčianská 9, Nová Dubnica, Slovenská republika, číslo oznámeného subjektu 1293, vydáno  
osvědčení o stálosti vlastností **CE 1293-CPD-0244**.
- 8. Evropské technické posouzení:** Neaplikováno
- 9. Vlastností uvedené v prohlášení:**

Základní charakteristiky	Vlastnost	EN 54-7:2000 + A1:2002	EN 54-5:2000 +A1:2002
Jmenovité aktivační podmínky/citlivost, zpoždění reakce a funkce v podmínkách požáru	vyhovující	4.8, 5.2 - 5.4, 5.6, 5.7, 5.18	4.2, 4.3, 5.2 - 5.6, 5.8
Provozní spolehlivost	vyhovující	4.2 - 4.7, 4.9 - 4.11	4.4 - 4.11
Kolísání napájecího napětí	vyhovující	5.5	5.7
Stálost provozní spolehlivosti a zpoždění reakce a odolnosti vůči teple	vyhovující	5.8, 5.9	5.9, 5.10
Stálost provozní spolehlivosti: odolnost vůči vibracím	vyhovující	5.13 - 5.16	5.14 - 5.17
Stálost provozní spolehlivosti: odolnost vůči vlhkosti	vyhovující	5.10, 5.11	5.11 - 5.12
Stálost provozní spolehlivosti: odolnost vůči korozi	vyhovující	5.12	5.13
Stálost provozní spolehlivosti: elektrická stabilita	vyhovující	5.17	5.18

**10. Vlastnost výrobku uvedeného v bodě 1 a 2 je ve shodě s vlastnostmi uvedenými v bodě 9.**  
Toto prohlášení o vlastnostech je vydáno na výhradní odpovědnost výrobce uvedeného v bodě 4.

V Jablonci nad Nisou, dne: 1.7.2013

Miroslav Jarolím  
ředitel



Tel: 483 559999  
Fax: 483 313183  
E-mail: [prodej@jablotron.cz](mailto:prodej@jablotron.cz)

## DECLARATION OF PERFORMANCE

ACCORDING TO REGULATION EU No 305/2011 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL  
laying down harmonised conditions for the marketing of construction products  
No. CPR\_003\_2013

- 1. Product identification code:** SD-282ST
- 2. Type identification:** Combined smoke and heat detector with relay
- 3. Intended use:** Fire detection in buildings
- 4. The manufacturer**  
**Name:** JABLOTRON ALARMS a.s..  
**Address:** Pod Skalkou 4567/33, Jablonec nad Nisou, Czech Republic, Postcode: 466 01  
**Company number:** CZ28668715
- 5. Authorized representative:** Not applied
- 6. Assessment and verification of constancy of performance:** System 1
- 7. Performed type testing and the initial inspection of the manufacturing plant and of the factory production control:**  
EVPÚ a.s., Trenčianská 9, Nová Dubnica, Slovak Republic, notified body 1293, issued certificate of constancy performance **CE 1293-CPD-0244.**
- 8. European Technical Assessment:** Not apply
- 9. Declared performance:**

Essential characteristic	Performance	EN 54-7:2000 + A1:2002	EN 54-5:2000 +A1:2002
Nominal activation conditions/sensitivity, response delay and performance under fire condition	pass	4.8, 5.2 - 5.4, 5.6, 5.7, 5.18	4.2, 4.3, 5.2 - 5.6, 5.8
Operational reliability	pass	4.2 - 4.7, 4.9 - 4.11	4.4 - 4.11
Tolerance to supply voltage	pass	5.5	5.7
Durability of operational reliability, response delay, temperature resistance	pass	5.8, 5.9	5.9, 5.10
Durability of operational reliability, vibration resistance	pass	5.13 - 5.16	5.14 - 5.17
Durability of operational reliability, humidity resistance	pass	5.10, 5.11	5.11 - 5.12
Durability of operational reliability, corrosion resistance	pass	5.12	5.13
Durability of operational reliability, electrical stability	pass	5.17	5.18

- 10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.**

This declaration of performance is issued under the sole responsibility of the manufacturer.

Place: Jablonec nad Nisou, Date: 1.7.2013

Miroslav Jarolím  
Managing director



Phone: +420 483 559 911  
Fax: +420 483 313 183  
E-mail: [export@jablotron.cz](mailto:export@jablotron.cz)